


NAGAR PALIKA PARISHAD, MUZAFFARNAGAR

From :

The Health Officer
Nagar Palika Parishad
Muzaffarnagar




Ref : 248

Date : 10-04-2024

It is certified that an inspection team headed by **Atul Kumar, Nagar Swasthya Adhikari** from **Nagar Palika Parishad, Muzaffarnagar** inspected the **M.G. Public School, Circular Road, Muzaffarnagar** on **04-04-2024** and found that the **M.G. Public School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/U.T. Govt.

The above is valid for a period of 2 years.

Signature with Seal : 
 Name : Atul Kumar **नगर स्वास्थ्य अधिकारी**
नगर पालिका परिषद्
मुजफ्फरनगर
 Designation : Nagar Swasthya Adhikari


Name & Address of the Office/Department : Nagar Palika Parishad, Muzaffarnagar

To


M.G. Public School

Circular Road, Muzaffarnagar

For Moti Ram Gopi Chand Charit...


Chairman


Chairman
M.G. Public School
Circular Road, Muzaffarnagar


Principal
M.G. Public School
Circular Road, Muzaffarnagar



District Level Water Analysis Laboratory, U.P. Jal Nigam(Rural) Muzaffarnagar

Address- Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam(Rural),
464/47, South civil Line, Muzaffarnagar, U.P. Pin-251001,

Test Report

Report No:	MZN/W- 02-2024/2	Issue Date:	18-04-2024	ULR No	
Rept No:				Page No	01/1
Cont. Person:	Mr. Anupam Kumar Jain(Q.M)	Address:	Office of Executive Engineer, Khand karyalay, U.P Jal Nigam(Rural), 464/47, South civil Line, Muzaffarnagar	Mob:	8979159702

Customer Details

Office Name and Address	M.G Public school Circular Road Muzaffarnagar (U.P)
Ref Letter No & Date	00

Basic details of sample

District	Muzaffarnagar	Block	Muzaffarnagar
Gram Panchayat	Muzaffarnagar	Village	Muzaffarnagar
Habitation	M.G Public school	Location	M.G Public school Circular Road
Water Source	Submersible	Sample No.	M/8844
Quality of Sample	Received in good Condition	Date of S.C.	15-04-2024
Receiving Date	15-04-2024	S. Collector	By Customer
Sample Depositor	M.G Public school	Sampling Method	
Analysis Start Date	16-04-2024	Analysis Completion Date	16-04-2024

Technical Data of Analysis

1	Analyzed parameters	Unit of Measurement	Observed Value	Specified Values as per BIS 10500 (2017)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
2	3	4	5	6	7	
1	pH @ 25°C	-	7.88	6.5-8.5	6.5-8.5	IS 3025(Part 11): 2022
2	Total Dissolved Solids	mg/L	455.33	500	2000	IS 3025(Part 16): 2023
3	Chloride	mg/L	7.998	250	1000	IS 3025(Part 32): 2019
4	Total Alkalinity	mg/L	332.00	200	600	IS 3025(Part 23): 2023
5	Total Hardness	mg/L	332.26	200	600	IS 3025(Part 21): 2019
6	Nitrate	mg/L	23.997	45.0	45.0	APHA 24 th Edition 4500- NO ₃ Method-D(UV Screening):2023
7	Fluoride	mg/L	0.305	1.0	1.5	APHA 24 th Edition 4500- F Method-C (Electrode Method):2023
8	Calcium	mg/L	85.50	75.0	200	IS 3025(Part 40): 2019
9	Magnesium	mg/L	28.86	30.0	100	IS 3025(Part 46): 2023 (Calculation Method)
10	Iron	mg/L	0.126	1.0	1.0	APHA 24 th Edition 3500- Fe Method-B (1,10Phenathroline): 2023
11	Colour	Hazen	-	5.0	15.0	IS 3025(Part 4):2021
12	Odour	-	Odorless	Agreeable	Agreeable	IS 3025(Part 5):2022
13	Total coliform	CFU	0.0	Shall not be detected in 100 ml sample	Shall not be detected in 100 ml sample	IS 15185 2016
14	E.Coli	CFU	0.0	Shall not be detected in 100 ml sample	Shall not be detected in 100 ml sample	IS 15185 2016
15	Free residual chlorine	mg/L	0.0	0.2	1.0	IS 3025(Part 26): 2021
16	Turbidity	NTU	1.0	1.0	5.0	IS 3025(Part 10): 2023
17	Conductivity	mS/cm	0.904			IS 3025(Part 14): 2023

Note

- This Certificate refers only to the particular sample(s) submitted for testing.
- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained.
- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports

Reviewed by
Mohit Kumar
(Technical Manager)

Mohit Kumar

Authorized Signatory:
Anupam Kumar Jain
(Quality Manager)

Anupam Kumar Jain

Laboratory Contact details Email- kumarakjain99@gmail.com , Mob- 8979159702

*****End of Report*****

For Moti Ram Gopi Chand Charitable Trust

Chairman

Mohit Kumar
Chairman
M.G. Public School
Circular Road, Muzaffarnagar

Anupam Kumar Jain
Principal
M.G. Public School
Circular Road, Muzaffarnagar

